
Measurement Log / BA

V1.68.1

IEC 60156:1995

Sample Number **301601**

TEST START 2010-03-04 18:59

Test 1	57.1 kV
Test 2	70.0 kV
Test 3	51.4 kV
Test 4	63.1 kV
Test 5	66.7 kV
Test 6	61.3 kV

TEST END 2010-03-04 19:17 all values (rms)

Mean **61.6 kV**

Std. Dev. **6.1 kV**

Range **18.6 kV**

Oil Temperature **27 °C**

Test Frequency **60 Hz**

